



NOTES:

1. 12" STABILIZED SUBGRADE MIN. LBR 40 COMPACTED TO 98% A.A.S.H.T.O. T-180 CAPABLE OF SUPPORTING 32 TONS.
2. THE BASE COURSE SHALL BE LIMEROCK (70% CALCIUM), 8" THICK COMPACTED IN ACCORDANCE WITH A.A.S.H.T.O. SPECIFICATION T-180 TO 98% DENSITY.
3. ALL ORGANIC AND YIELDING MATERIAL WITHIN THE LIMITS SHOWN SHALL BE REMOVED AND REPLACED WITH CLEAN FILL, THE SUBBASE SHALL EXTEND 12" BELOW THE BASE COURSE, SHALL HAVE A MINIMUM DRY DENSITY OF 115 PCF AND SHALL BE COMPACTED TO 98% OF MAXIMUM DRY DENSITY PER A.A.S.H.T.O. SPECIFICATION T-180, METHOD "C". MINIMUM LBR TO BE 40.

STABILIZED FIRE ACCESS ROAD DETAIL

N.T.S

REVISIONS		
No.	Date	Remarks

Date: 9/1/2024

By: _____

Seal: _____

**TAMARAC FIRE RESCUE
STANDARD DETAILS**

CITY OF TAMARAC, BROWARD COUNTY, FLORIDA