



Tents and Canopy Requirements

1. An affidavit (California State Seal or Equivalent) attesting to the information relative to the flame-retardant treatment of fabrics shall be provided
 - Provide a sample swatch of fabric to be used for all new installations
2. Approved No Smoking signs shall be conspicuously posted.
3. Provide approved receptacles for the disposal of lighted smoking materials at all entrances.
4. One 2-A fire extinguisher with a current annual service tag shall be provided in every tent/canopy having less than 1,000 square feet and also one for each additional 2,000 square feet or fraction thereof.
5. At least one 40-BC fire extinguisher shall be provided for each kitchen, mess hall, power generator or transformer and at locations where flammable liquids are used, stored or dispensed.
6. There shall be no cooking or open flames under tent.
7. All cooking shall be at least 10 feet from the building.
8. Emergency vehicle access to the building must be clear of any and all obstructions.
9. At every exit and wherever otherwise required to clearly indicate the direction of egress, an exit sign with letters at least 6" high shall be provided. Tent shall not have sidewalls.
10. Outside of tent area shall be cleared of all vegetation by a minimum of 10 feet (surrounding tent area). Example: Trees, shrubs, tall grass, etc.
11. All paved roads and turning area shall have at least 13 ½ of vertical clearance, to allow for the passage of emergency vehicles.
12. A pre-event fire safety inspection shall take place prior to the event.
13. Final approval for event is contingent upon passing the pre-event fire safety inspection.

Plans Reviewer: Inspector Mark Micciche
Phone: 954-597-3811

"Committed to Excellence...Always."